

FIRE COMPANY CERTIFICATION:			
NAME & TITLE _____			
NATURAL RESOURCES CONSERVATION SERVICE CERTIFICATION:			
NAME & TITLE _____			
FREEZE PROTECTION			
12" PVC FROM HEAD ASS'Y TO BELOW NORMAL WATER: ANNULAR SPACE FILLED WITH INSULATION FOAM. (PREMOLDED OR EXPANDING FOAM)			
GUARD POSTS - SEE NOTE #1			
YES ☐ NO ☐			

ITEM	MARK	QTY.	UNIT
BILL OF MATERIALS			
8" HYDRANT ASSEMBLY - 90° BEND	1	1	EACH
HYDRANT CAP	2	1	EACH
8" 3" PVC STRAINER	3	1	EACH
8" SCH. 40 PVC 90° ELBOW	4	1	EACH
8" SCH. 40 PVC PIPE-RISER	5	1	LN., FT.
8" SCH. 40 PVC PIPE	6	1	LN., FT.
8" SCH. 40 PVC COUPLINGS	7	1	EACH
8" STRAINER CAP	8	1	EACH
PRIMER CLEANER			CAN
PVC GLUE			CAN
UNDER-WATER SUPPORT	9	1	LN., FT.
12" SCH. 40 PVC PIPE	10	1	LN., FT.
12" SCH. 40 PVC CAP	11	1	EACH

ITEM	SITE DATA
POOL	_____
DROUGHT POOL	_____
MINIMUM DRAIN	_____
MAXIMUM DRAIN	_____
AVAILABLE WATER AT NORMAL LEVEL	_____
AVAILABLE WATER AT DROUGHT LEVEL	_____

PROFILE

NOTES:

1. FOR GUARD POSTS, IF REQUIRED, SHALL BE _____

2. UNDER-WATER SUPPORT CAN BE COMMERCIAL KIT OR CONSTRUCTED FOR LOCAL CONDITIONS.

NOT TO SCALE

COUNTY, PENNSYLVANIA	
8" DRY HYDRANT - VERTICAL	
Drawn by _____	Date _____
Checked by _____	
Approved by _____	

PA-057C
PA-057C