

FIRE COMPANY CERTIFICATION: NAME & TITLE _____ NATURAL RESOURCES CONSERVATION SERVICE CERTIFICATION: NAME & TITLE _____		FEEZE PROTECTION 12" PVC FROM HEAD ASS'Y TO BELOW NORMAL WATER ANNUAL SPACE FILLED WITH INSULATION FOAM. (PREMOULDED OR EXPANDING FOAM) GUARD POSTS - SEE NOTE #1 YES ____ NO ____	
BILL OF MATERIALS		SITE DATA	
ITEM	MARK	QUAN.	UNIT
8" HYDRANT ASSEMBLY - 45° ELBOW	1	1	EACH
HYDRANT CAP	2	1	EACH
8" 3' PVC STRAINER	3	1	EACH
8" SCH. 40 PVC 45° ELBOW	4	1	EACH
8" SCH. 40 PVC PIPE-RISER	5	1	UN. FT.
8" SCH. 40 PVC PIPE	6	1	UN. FT.
8" SCH. 40 PVC COUPLINGS	7	1	EACH
UNDER-WATER SUPPORT	8	1	CAN
PVC GLUE	9	1	CAN
PRIMER CLEANER			EACH
8" STRAINER CAP			EACH
POOL		ACRES	
DROUGHT POOL	---	FEET	
MINIMUM DRAIN	---	FEET	
MAXIMUM DRAIN	---	GAL.	
AVAILABLE WATER AT NORMAL LEVEL	---	GAL.	
AVAILABLE WATER AT DROUGHT LEVEL	---	GAL.	

PROFILE
NOT TO SCALE

NOTES:
1. FOR GUARD POSTS, IF REQUIRED, SHALL BE
2. UNDER-WATER SUPPORT CAN BE COMMERCIAL KIT OR
CONSTRUCTED FOR LOCAL CONDITIONS.

Designed	_____	Date	_____
Drawn	_____		_____
Checked	_____		_____
Approved by	_____		_____

_____ COUNTY, PENNSYLVANIA

8" DRY HYDRANT - SLOPING

NRCS
Natural Resources Conservation Service
United States Department of Agriculture

Form No. PA-058C-001
Drawing No. PA-058C-001
Date: 10/1/00